



FIRE SAFETY PERMIT

Date:

Business:

Address:

Phone:

The following permit has been issued to:

Permit No:

Type of Permit: **Type I Permit**

Issued Date:

Effective Date:

Expiration Date:

Times:

Notes:

Portable LP-gas or other cooking equipment shall not be stored or used as follows:

Within 5 ft. of any combustible exterior wall, within 5 ft. vertically or horizontally, of an opening in any wall, within or under any building overhang, within 20 ft. of tents.

One portable fire extinguisher with a minimum 4-A rating shall be present.

Approval is contingent on payment of the fee of \$ 42.00 and adherence to the notes above. Please contact Woodbury Fire Marshal's Office for more information if needed.

Date:

Joseph Buono Fire Marshal

This certificate must be posted in a conspicuous location at the above premises. It is the applicant's responsibility to comply with other applicable, health, police, building construction requirements for such matters as electrical, plumbing, or mechanical activities.